



NOTES:

1. DROP OF GRADE THROUGH MANHOLE SHALL BE 0.1-FT UNLES OTHERWISE APPROVED BY CITY ENGINEER.
2. MANHOLES SHALL COMPLY WITH WSDOT STANDARD SPECIFICATIONS FOR TYPE III MANHOLES
3. PIPES SHALL PROTRUDE NO MORE THAN 1-inch INTO MANHOLE.

6/8/06
Date

APPROVED
City of Oak Harbor
Engineering Dept.

Signature



City of
Oak Harbor
ENGINEERING DEPARTMENT
865 SE Barrington Drive
Oak Harbor, WA 98277

TYPICAL SECTION
OUTSIDE DROP CONNECTION
TYPE III SEWER MANHOLE

SS-6Outside Drop Connect Type 3 Manhole.dwg

REVISED 3-20-06